



OFFICE OF THE EXECUTIVE ENGINEER PWD (R&B) CONST. DIVN. NO. II JAMMU


The Principal
Kendriya Vidyalaya
Domana (Jammu)
Jammu

NO. 5658-22

DT: 16.7.2021

Subject: Building Safety Certificate


As reported by the Assistant Executive Engineer PWD (R&B) Sub - Division City - Ist. Jammu vide letter No. 344/Aee/City-Ist dt. 09-07-2021 that the building is a temporary structure. The walls are of the AC sheets on both sides with thermocol in between and roofing is of CGI sheet. Since the building is temporary so the building safety certificate cannot be issued.


Executive Engineer
PWD (R&B) Const. Divn. No. II
Jammu

Copy to the:-

- 1/- Assistant Executive Engineer PWD (R&B) Sub - Division City - Ist. Jammu for information.
- 2/- Head Draftsman Divisional Office.

Handwritten notes:
collected
22


Principal
केन्द्रीय विद्यालय / Kendriya Vidyalaya
दमना पुराण क्षेत्र, जम्मू - 181206
Domana Puranoo Camp, Jammu - 181206