

Office of the Director Fire & Emergency Services, J&K
Jammu/Srinagar

The Principal
Kendriya Vidyalaya
Domana Purkhoo
Jammu

No. DFES/ED/2022-04(FC-7079422)

Dated: 02/02/2024

Sub: Fire Safety Certificate

Ref: Your online application submission dated: 23/01/2024 (F1026-935444)

The inspection of above said school was got carried out by the inspecting officer of this department. During inspection it was found that the management has installed First Aid Fire Extinguisher in their school premises. The school is about 07 Km away from Fire and Emergency Station Canal (Lower Muthi) and is approachable for fire appliances in case of any emergency. Since the school is already functioning as such, the management can proceed ahead for operation subject to adopt the following fire safety precautionary measures in letter and spirit forthwith:-

- 04 Nos. of ABC Stored Pressure Type Fire Extinguisher of 04 Kg capacity each should be provided at strategic locations in the school building and 01 No. of CO₂ Type fire extinguisher of 4.5 Kg capacity should be provided near main electric switch board panel in addition to already existing fire extinguishers.
- All exits/entrances should be kept open and free from any obstruction for easy and safe evacuation of inmates during any emergency.
- All electric installations existing in the building should be concealed conduit type.
- First Aid Fire fighting system installed in the school building should be checked periodically. Staff and management should be fully trained in handling / operating of fire fighting system installed in the school building. The management shall intimate this office in writing after each quarter that the fire fighting equipments installed in the school are functioning.
- All class room and examination halls having seating capacity for more than 45 students need to be provided with two exits.
- The corridor of the building shall not be used for any kind of storage.
- No Hazardous material should be kept inside of the school premises (especially LPG cylinder, Petrol and Diesel etc.). Any deviation found in this regard, this clearance will be treated automatically withdrawn/cancelled.
- The management of the school shall be wholly and solely responsible for keeping the fire fighting system in working condition 24x7 and safe evacuation of its students during any mishap.
- The management must provide two exits on opposite directions in each block for safe evacuation of students as well as staff in case of any emergency/other calamities.
- At present school is having eight single storied fiber sheet tin roofed blocks. As such no addition / alteration should be made by the school management in the existing structure without prior information from this department. Any deviation found in this regard, this clearance will be treated automatically withdrawn/cancelled.
- The department can make a surprise visit to your school at any time. During the visit if the fire fighting system (i.e. existing as well as proposed) found defunct and deviation, this clearance issued shall be treated automatically withdrawn/cancelled.
- This clearance shall be subject to outcome of any dispute/investigation/enquiry/ trial if any pending before any Court of Law/investigation agency. This clearance shall not confirm any title upon the person/company in whose favor it is issued.
- The validity of this clearance shall remain in force for one year and same needs to be renew yearly after inspection/checking of entire fire fighting system (i.e. existing as well as proposed) installed in the school building. However, before granting permission/recognition/extension or renewal thereof, the authority concerned shall satisfy himself in terms of conditions laid down in SRO-123 of 2010 and SRO-292 of 2018, issued by Education Department with regard to physical facilities and also ensure the fire safety measures/guidelines given to the proprietor by this department are fully complied with.

Director
Fire & Emergency Services, J&K
Jammu/Srinagar

Kumar Fairman
1-21/3/प्रो.वार्ड

Principal
केन्द्रीय विद्यालय / Kendriya Vidyalaya
दमना पुरखु कैंप-जम्मू-181208
Domana Purkhoo Camp