

Office of the Joint Director Fire & Emergency Services
Jammu Range, Jammu

The Principal
Kendriya Vidyalaya Damanaa
at Purkhoo, Tehsil Bhalwal
District Jammu

No: JDJF&ES/FPI 247

Dated: 14.01.2021

Sub: Provisional Fire Safety Certificate.

Ref: Your Letter No.F.16772/KVD/2020-21 dated: 07.08.2020.

Sir,

The inspection of above said school was got carried out by the inspecting officer of this department. During inspection it was found that most of the fire extinguishers already installed in the school premises are needs to be refilled immediately. The site is about 07 Km away from Fire & Emergency Station Canal Jammu and is approachable for fire appliances in case of any emergency. Since the school is already functioning as such, the management can proceed ahead for operation provisionally subject to strictly adopt the following fire safety measures in letter and spirit forthwith:--

1. The fire extinguishers which were found empty during inspection should be refilled immediately by the management.
2. 04 Nos. ABC Type Fire Extinguishers should be provided at appropriate locations in the school premises and 01 No. of CO₂ Type Fire Extinguisher of 4.5 Kg capacity should be provided near main electric switch board panel in addition to already existing fire extinguishers.
3. All exits/entrances should be kept open and free from any obstruction for easy and safe evacuation of inmates during any emergency.
4. First Aid firefighting system installed in the school building should be checked periodically. Staff and students should be fully trained in handling/operating of firefighting system installed in the School building. The management shall intimate the office of Deputy Director, Fire & Emergency Services Command Jammu after each quarter that the firefighting equipment installed in the school are functioning.
5. All class rooms and examination halls having seating capacity for more than 45 students need to be provided with two exits.
6. The corridor of the building shall not be used for any kind of storage.
7. No Hazardous material should be kept inside of the school premises (especially LPG cylinder, Petrol and Diesel etc.). Any deviation found in this regard, this clearance will be treated withdrawn/cancelled.
8. One window of each class room should be without iron grill so that it can be used for safe evacuation of inmates during any mishap.
9. The management of the school shall be wholly and solely responsible for keeping the firefighting system in working condition 24x7 and safe evacuation of its students during any mishap.
10. At present school is having six tin roofed shed and two concrete single storied barrack type sheds. As such no addition/alteration should be made by the school management in the existing structure without prior permission from this department. Any deviation found in this regard, this provisional clearance will be treated withdrawn/cancelled.
11. Telephone numbers of nearest Fire & Emergency Stations should be displayed.
12. The validity of this provisional clearance shall remain in force for six months and same needs to be renewed after checking of firefighting system installed in the school.

Yours Sincerely


प्राचार्य

Principal

केंद्रीय विद्यालय / Kendriya Vidyalaya
दमना पुरखु कॉम्प-जम्मू-181206
Domana Purkhoo Camp, Jammu-181206


Joint Director
Fire & Emergency Services
Jammu Range, Jammu

